



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Orchard Hill Elementary School, 244 Orchard Rd., Skillman, NJ

PAS Project ID : P22-09917

Matrix : Drinking Water

Report Date : 8/26/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-09917-01	OHE-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/25/22 06:10	8/25/22 15:26
P22-09917-02	OHE-1-111-CF-R	Lead	2.89	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/25/22 06:12	8/25/22 15:54

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director