



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
400 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Montgomery Upper Middle School, 375 Burnt Hill Road
PAS Project ID : P22-04134

Matrix : Drinking Water
Report Date : 5/23/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-04134-01	UMS-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/18/22 05:47	5/19/22 11:09
P22-04134-02	UMS-1-Kitchen-FPI-P	Lead	2.61	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/18/22 05:48	5/19/22 11:12
P22-04134-03	UMS-1-Kitchen-FP2-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3113 B	5/18/22 05:49	5/19/22 11:26
P22-04134-04	UMS-1-Kitchen-FP3-P	Lead	2.3	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/18/22 05:49	5/19/22 13:49
P22-04134-05	UMS-1-Kitchen-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/18/22 05:52	5/19/22 11:48
P22-04134-06	UMS-1-Cafeteria-WC-P	Lead	9.42	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/18/22 05:53	5/19/22 11:51
P22-04134-07	UMS-1-H Guidance-DWI-P	Lead	2.3	ug/L	1	2.00	0.90	15.0 *	SM 3113 B	5/18/22 05:55	5/19/22 11:58
P22-04134-08	UMS-1-H Guidance-DW2-P	Lead	2.22	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/18/22 05:56	5/19/22 12:02

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director